

**Cost Effective Filtration System to Improve the Water
Quality in Rainwater Tanks**

By

Benjamin George Kus



A thesis submitted in fulfilment of the requirements for the degree of

Doctor of Philosophy (Engineering)

Faculty of Engineering and Information Technology

University of Technology, Sydney

Australia, 2014

Certificate of original authorship

I certify that the work in this thesis has not previously been submitted for a degree nor has it been submitted as part of requirements for a degree except as fully acknowledged within the text.

I also certify that the thesis has been written by me. Any help that I have received in my research work and the preparation of the thesis itself has been acknowledged. In addition, I certify that all information sources and literature used are indicated in the thesis.

Signature of Candidate:

Date:

Production Note:
Signature removed prior
to publication.

7 February 2014

Benjamin Kus

Acknowledgement

It would not have been possible to achieve this doctorate of philosophy without the help and support of all the people around me. I am highly appreciative to everyone for their help and support during my research.

My first thanks and gratitude goes to my principal supervisor A.Prof. Jaya Kandasamy for his inspiration, motivation and guidance throughout this research. I would also like to show my thanks and gratitude to my co-supervisors Prof. S. Vigi Vigneswaran and Dr Ho Kyong Shon.

I am particularly thankful to the academic and technical support of the University of Technology, Sydney and its staff, especially Phyllis for all my academic support and A. Prof. Huu Hao Ngo, Rami Hadad and David Hooper for their help and support in the environmental and hydraulics laboratories.

I would like to thank my colleagues and friends that I have enjoyed working alongside during this time: Johir, Thamer, Chinu, Ibrahim, Danious, Dang, Jani, Than, Wen, Ghausul, Yousuf, Monami, Debbie, Greg, Javeed, Rupak and Lazlo.

I would like to show my gratitude to Australian Research Council (ARC), Amit Chanan, Isabelle Gheti and Glen Moody from Kogarah City Council for their encouragement and financial support of the study.

I am thankful to my parents Suzanne and George for providing me with great opportunities in life and encouraging me to enter the field of Engineering. I would also like to thank the rest of my family and friends who have also provided great support during this time.

Above all, I would like to give special thanks to my dear wife Sarah and my beautiful children Abigail and Olivia. Completing my PhD would not have been possible without their love, continuous support, enduring patience and understanding during this time.

Contents

1. Introduction.....	1-1
1.1. Scarcity of water in Australia.....	1-2
1.2. Worldwide scarcity of water.....	1-2
1.3. Alternative sources of water.....	1-3
1.4. Pollutants in rainwater.....	1-5
1.5. First flush.....	1-6
1.6. Aim of study.....	1-6
1.7. Objectives of this study.....	1-7
1.8. Structure of the Study.....	1-8
2. Literature Review.....	2-1
2.1. Introduction.....	2-2
2.2. Rainwater harvesting.....	2-3
2.3. Water demand in Australia.....	2-5
2.4. Rainwater harvesting in Australia.....	2-20
2.5. Characterisation of water.....	2-24
2.6. Methods of water filtration.....	2-31

2.7.	Stormwater	2-45
2.8.	Water Sensitive Urban Design treatment	2-53
2.9.	Evaluation of WSUD.....	2-55
3.	Experimental Investigation	3-1
3.1.	Introduction	3-2
3.2.	Experimental materials.....	3-2
3.3.	Experimental methods.....	3-30
3.4.	Pilot scale rainwater treatment system	3-53
4.	Characterisation of Rainwater.....	4-1
4.1.	Characterisation of metropolitan rainwater tanks	4-2
4.2.	Characterisation of outer Sydney rural raintank water.....	4-12
4.3.	Characterisation of the first flush in Sydney metropolitan rainwater tanks	4-19
4.4.	Comparison of the various tested water sources	4-31
4.5.	Conclusion.....	4-33
5.	Water Demand	5-1
5.1.	Introduction	5-2
5.2.	Background and data	5-2
5.3.	Results	5-8

5.4.	Conclusions	5-25
6.	Granular Activated Carbon (GAC) Filter for Rainwater Treatment.....	6-1
6.1.	Introduction	6-2
6.2.	Granular Activated Carbon (GAC) adsorption filter – first experiment	6-2
6.3.	GAC adsorption filter – second experiment.....	6-15
6.4.	Pilot scale GAC adsorption filter	6-24
6.5.	Conclusion.....	6-31
7.	Membrane Micro-Filtration	7-1
7.1.	Introduction	7-2
7.2.	Clean membrane flux determination of micro-filtration membranes.....	7-2
7.3.	Ultra Flo hollow fibre micro-filtration under gravitational head	7-4
7.4.	INGE membrane filtration with pre-treatment under gravitational head	7-23
7.5.	Conclusion.....	7-34
8.	Stormwater Harvesting Pilot Scale Plant	8-1
8.1.	Introduction	8-2
8.2.	Laboratory scale experiments.....	8-2
8.3.	Steriflow membrane filtration	8-9
8.4.	Staged media filtration for stormwater treatment.....	8-15

8.5. Conclusion.....	8-29
9. Pilot Scale Rainwater Tank.....	9-1
9.1. Introduction	9-2
9.2. Results and discussion.....	9-4
9.3. Conclusion.....	9-1
10. Conclusion and Recommendations	1
10.1. Introduction	2
10.2. Characterisation of rainwater.....	2
10.3. Water demand.....	3
10.4. GAC adsorption filtration.....	4
10.5. Membrane micro-filtration	5
10.6. Stormwater harvesting pilot scale plant.....	6
10.7. Design and operational simulation of a pilot scale rainwater tank.....	7
10.8. Future research.....	8
Appendix A - Water Demand High Resolution Figures.....	A-1
Appendix B - Author's Contribution to the Development of the Carlton Stormwater Harvesting Plant.....	B-1
References.....	R-1

List of tables

Table 2.1	Households with rainwater tanks in 2001 (ABS, 2001).....	2-8
Table 2.2	Households with rainwater tanks in 2007 & 2010 (ABS, 2010).....	2-8
Table 2.3	Main source of drinking water (ABS, 2001).....	2-9
Table 2.4	Main source of drinking water in Australia (ABS, 2010).....	2-10
Table 2.5	Main source of water for gardening (Houses with a garden) (ABS, 2010)	2-11
Table 2.6	Household water use per capita (ABS, 2006b).....	2-12
Table 2.7	Household water use per household (ABS, 2006b)	2-12
Table 2.8	Composition of household water usages 2000-01 (ABS, 2004).....	2-13
Table 2.9	Average water demands derived from household water usage at each location from Table 2.7 (2004-05) and Table 2.8 (ABS, 2004; ABS, 2006b).....	2-14
Table 2.10	Households with water-saving products 1998 - 2010 (ABS, 2010).....	2-14
Table 2.11	Average water demands derived for households at each location	2-15
Table 2.12	Typical contaminants within rainwater tanks (Australian Government DHA, 2004)	2-22
Table 2.13	Australian drinking water guideline limits.....	2-25
Table 2.14	Characteristics of rapid filters:	2-32

Table 2.15	Estimated treatment performance summary (CSIRO, 1999).....	2-34
Table 2.16	Pollution retention rates for sand filters (Chiew et al, 1997).....	2-35
Table 2.17	Comparing MF and UF Membrane Processes (Wagner, 2001).....	2-41
Table 2.18	Types and causes of urban stormwater pollution (adapted from CSIRO, 1999)	2-50
Table 2.19	Potential Benefits and Limitations of WSUD.....	2-56
Table 2.20	Stormwater indicative targets criteria for reuse application (DEC, 2006).....	2-60
Table 3.1	Characteristics of Metropolitan Rainwater Tanks	3-6
Table 3.2	Characteristics of Rural Rainwater Tanks	3-8
Table 3.3	Water quality parameters and measurement methods (Eaton et al., 2005).....	3-10
Table 3.4	Relationship between the size in nm and MW in Daltons	3-11
Table 3.5	Physical properties of Granular Activated Carbon (GAC).....	3-14
Table 3.6	Physical properties of Anthracite.....	3-15
Table 3.7	Physical properties of Sand.....	3-15
Table 3.8	Physical properties of Steriflow stainless steel micro-filtration membrane	3-17

Table 3.9	Physical properties of INGE Watertechnologies AG Multibore micro-filtration membrane.....	3-19
Table 3.10	Physical properties of Ultra Flo hollow fibre micro-filtration membrane... ..	3-20
Table 3.11	Physical properties of filter columns utilised in experiments	3-21
Table 3.12	Specifications of data logging equipment	3-22
Table 3.13	Cartridge Filter Specifications	3-24
Table 3.14	Physical properties of Watts (Ultra Flo) hollow fibre micro-filtration membrane	3-24
Table 3.15	Summary of rain events that were monitored for first flush runoff.....	3-34
Table 3.16	Flux decline gravitational head pressures and GAC analysed for Ultra Flo hollow fibre micro-filtration membrane with and without pre-treatment.....	3-42
Table 3.17	Flux decline gravitational head pressures analysed for INGE Watertechnologies AG Multibore micro-filtration membrane with GAC adsorption pre-treatment	3-43
Table 4.1	Laboratory analysis of rainwater tank samples.....	4-6
Table 4.2	Laboratory analysis of rural rainwater tank samples	4-16
Table 4.3	First flush rainwater samples from Event 1	4-26
Table 4.4	First flush rainwater samples from Event 2	4-27

Table 4.5	First flush rainwater samples from Event 3	4-28
Table 4.6	Comparison of Water Quality at T1 with ADWG, Rainfall and Potable Water	4-32
Table 5.1	SWC Water restrictions (Sydney Water, 2012a)	5-5
Table 5.2	Water savings by installing a rainwater tank in the Sydney Metropolitan Area	5-12
Table 6.1	Laboratory analysis of GAC adsorption filter - first experiment.....	6-13
Table 6.2	Laboratory analysis of GAC adsorption filter - second experiment	6-22
Table 6.3	Details of rainfall events captured by the pre-rainwater tank inline GAC adsorption filter	6-24
Table 6.4	Laboratory analysis of inline GAC adsorption filter upstream of rainwater tank	6-29
Table 7.1	Laboratory analysis of Ultra Flo hollow fibre micro-filtration membrane pollutant removal without pre-treatment.....	7-17
Table 7.2	Ultra-Flo membrane filtration with GAC adsorption pre-treatment.....	7-20
Table 7.3	INGE membrane filtration with GAC adsorption pre-treatment.	7-31
Table 8.1	Filtrated water quality after different pre-treatments (raw water turbidity = 25.3 NTU; TOC = 5.35 mg/L).....	8-5
Table 8.2	Turbidity, TOC and Heavy Metals results of Steriflow filtration system....	8-7

Table 8.3	Heavy Metals results of Steriflow filtration system with GAC adsorption as pre-treatment.....	8-8
Table 8.4	TOC results (based on 7 samples taken daily for 3 consecutive days) .	8-17
Table 8.5	Turbidity results (based on 7 samples taken daily for 3 consecutive days)	8-21
Table 8.6	Removal of heavy metals with various treatment trains	8-24
Table 8.7	Fractionation of organic compounds by LC-OCD.....	8-26
Table 9.1	Cartridge Operation.....	9-5
Table 9.2	Turbidity and TOC results based on samples taken during the pilot trial....	9-8
Table 9.3	Heavy metal results based on samples taken during the pilot trial	9-10
Table 9.4	Fractionation of organic compounds by LC-OCD.....	9-12

List of figures

Figure 1.1	Diagram denoting structure of PhD research.....	1-8
Figure 2.1	Schematic of typical rainwater tank RWH processes (Coombes et al., 2008)	2-21
Figure 2.2	Formation of biofilm (adapted from Sheikholeslami, 2007)	2-38
Figure 2.3	Pathogen removal ability of membrane filtration (adapted from Allgeier et al., 2005)	2-41
Figure 3.1	Locations of metropolitan rainwater tanks in Sydney (Google Maps, 2011)	3-4
Figure 3.2	Location of rural rainwater tanks in relation to Sydney (Google Maps, 2011)	3-5
Figure 3.3	Location of first flush rainwater in relation to the Sydney Basin (DECCW, 2009)	3-7
Figure 3.4	Photograph of Multi N/C 2000 analyser (Analytik Jena AG)	3-12
Figure 3.5	Photograph of Granular Activated Carbon	3-16
Figure 3.6	Photograph of Anthracite	3-16
Figure 3.7	Photograph of Sand	3-16
Figure 3.8	Photograph of Steriflow membrane inside of Perspex column.....	3-18

Figure 3.9	Photograph of INGE Multibore® membrane (INGE Watertechnologies AG 2010).	3-19
Figure 3.10	Photograph of cartridge filtration system	3-23
Figure 3.11	Photograph of cartridge filtration system	3-25
Figure 3.12	Construction of filter column filtration system – Constructing and reinforcing the base plate for stability	3-26
Figure 3.13	Construction of filter column filtration system – Painting of the base plate to protect against corrosion and add wheels for mobility	3-26
Figure 3.14	Construction of filter column filtration system – Constructing and assembly of supporting towers and filter column attachment brackets	3-27
Figure 3.15	Construction of filter column filtration system – Constructing and assembly of filter column attachments	3-28
Figure 3.16	Filter column filtration system in stormwater harvesting plant cabinet	3-29
Figure 3.17	Hydraulic flow lines of filter column filtration system	3-29
Figure 3.18	Ingleburn rainwater tank ID 1 rainfall and tank volume with MWD date in 2008	3-32
Figure 3.19	Schematic diagram of typical isolated rainwater tank and drainage system in a contemporary Australian house	3-34
Figure 3.20	Schematic diagram of GAC adsorption filter apparatus	3-36

Figure 3.21	Schematic diagram of pre-rainwater tank inline GAC adsorption filter ..	3-38
Figure 3.22	Schematic diagram of clean membrane flux determination under gravitational head. Note pump and filter column were used to simulate a constant gravity head.	3-40
Figure 3.23	Schematic diagram of Steriflow Filtration System micro-filtration clean membrane flux determination under pumped head.....	3-40
Figure 3.24	Carlton Stormwater Harvesting Plant, Kogarah, Sydney.....	3-44
Figure 3.25	Schematic diagram of GAC media filter column stormwater pre-treatment	3-47
Figure 3.26	Schematic diagram Steriflow filtration system in cross-flow configuration with circulation bleed valve reducing retentate concentration.	3-48
Figure 3.27	Schematic diagram of high flow GAC media filtration and Ultra Flo hollow fibre micro-filtration membrane under gravitational head.....	3-50
Figure 3.28	Schematic diagram of high flow Anthracite and GAC media filtration and Ultra Flo hollow fibre micro-filtration membrane under gravitational head	3-51
Figure 3.29	Schematic diagram of high flow Anthracite, Sand and GAC media.	3-52
Figure 3.30	Schematic diagram of Watts (Ultra Flo) hollow fibre micro-filtration membrane cartridge system under gravitational head with GAC adsorption pre-treatment	3-55
Figure 4.1	MWD of RWOM before/after roof contact of rainwater	4-10

Figure 4.2	MWD of RWOM showing the effects of ageing of rainwater in tank over 1-17 days	4-11
Figure 4.3	MWD of RWOM showing the ageing effects for long durations during which rainfall occurred	4-11
Figure 4.4	(a-h) Physical and chemical characteristics of wash-off values from a concrete tiled roof of an urban house compared with ADWG (2011) limit values	4-21
Figure 4.5	MWD of RWOM with the effects of continuous rainfall after the roof contact.	4-29
Figure 5.1	Variation in average water consumption in Sydney and its LGAs.	5-10
Figure 5.2	Water consumption for single residential houses in the Sydney metropolitan area.....	5-14
Figure 5.3	Average area, number of persons and water usage for single residential houses in Sydney.....	5-15
Figure 5.4	Socio-economic indicators in the Sydney metropolitan area.....	5-18
Figure 5.5	Water savings from rebated rainwater tanks in the Sydney metropolitan area	5-23
Figure 6.1	TOC influent and effluent of GAC adsorption filter experiments. S1 is data from the first experiment, S2 is from the second experiment. Backwash carried out on Day 25 (for S1) and Days 35, 60, 100, and 140 (for S2).	6-4

Figure 6.2	Graph combining TOC removal rate from both GAC adsorption filter experiments. S1 is data from the first experiment; S2 is from the second experiment. Backwash carried out on Day 25 (for S1) and Days 35, 60, 100, and 140 (for S2).	6-4
Figure 6.3	Graph of turbidity removal with GAC adsorption filter.....	6-8
Figure 6.4	Graph of total suspended solids removal with GAC adsorption filter ..	6-9
Figure 6.5	Graph of true colour removal with GAC adsorption filter	6-9
Figure 6.6	Graph of lead removal with GAC adsorption filter	6-9
Figure 6.7	Graph of iron removal with GAC adsorption filter	6-10
Figure 6.8	Graph of manganese removal with GAC adsorption filter	6-10
Figure 6.9	Graph of zinc removal with GAC adsorption filter	6-11
Figure 6.10	Graph of turbidity removal with GAC adsorption filter	6-19
Figure 6.11	Graph of total suspended solids removal with GAC adsorption filter	6-19
Figure 6.12	Graph of lead removal with GAC adsorption filter	6-19
Figure 6.13	Graph of iron removal with GAC adsorption filter	6-20
Figure 6.14	Graph of manganese removal with GAC adsorption filter	6-20
Figure 6.15	Graph of zinc removal with GAC adsorption filter	6-20
Figure 7.1	Clean membrane flux at incremental head pressures.....	7-4

Figure 7.2 Comparison of Ultra Flo hollow fibre micro-filtration membrane flux decline under various gravity head with and without GAC adsorption pre-treatment. 7-5

Figure 7.3 Comparison of INGE Watertechnologies AG Multibore micro-filtration membrane flux decline under various gravity heads with GAC adsorption pre-treatment.7-24

Figure 8.1 Comparison between pre-treatments and cross-flow microfiltration (stormwater; membrane area = 0.03 m²; pore size = 0.3 μm; cross flow velocity=0.5 m/s; pure water flux at IP=125±3 and OP=100±3 kPa is 0.44 m³/m².h; IP=Inlet pressure and OP=outlet pressure).....8-6

Figure 8.2 TOC with Steriflow membrane filter results followed by post-treatment with GAC8-11

Figure 8.3 Turbidity with Steriflow membrane filter treatment followed by post-treatment with GAC8-11

Figure 8.4 TOC results with GAC filter followed by membrane filter filtration ...8-18

Figure 8.5 TOC results with anthracite, GAC and membrane filter treatment8-18

Figure 8.6 TOC results with anthracite, sand, GAC and membrane filter treatment
.....8-19

Figure 8.7 Turbidity with results for the GAC filter followed by membrane filter8-22

Figure 8.8 Turbidity results with anthracite, GAC and membrane filter treatment8-22

Figure 8.9 Turbidity results with anthracite, GAC and membrane filter treatment8-23

Figure 8.10 Possible prototype application of high rate media filtration followed by membrane filtration membrane (operated under gravitational head).....8-28

Figure 9.1 Membrane flux decline over the duration of the pilot scale study. Also shown is the water head in the rainwater tank and the volume of water treated.9-5

Figure 9.2 TOC results with GAC filter followed by membrane filter filtration.9-7

Figure 9.3 Turbidity results with GAC filter followed by membrane filter filtration...
.....9-7

Nomenclature

A	=	Surface area (m ²)
Å	=	Average pore diameter
ABS	=	Australian Bureau of Statistics
AC	=	Activated Carbon
ADWG	=	Australian Drinking Water Guidelines
ANZECC Council	=	Australian and New Zealand Environment and Conservation Council
APAH	=	American Public Health Association
ASTM	=	American Standard Testing and Methods
BMP	=	Best Management Practice
BOD	=	Biological Oxygen Demand
BOM	=	Biodegradable Organic Matter
C _b	=	The concentration of particles in a feed water
°C	=	Degree Celsius
CC	=	Cubic centimetres
COD	=	Chemical Oxygen Demand
Da	=	Dalton
Dia.	=	Diameter
DOC	=	Dissolved Organic Carbon
DOM	=	Dissolved Organic Matter
DMF	=	Dual media filter
EfOM	=	Effluent Organic Matter
Eq.	=	Equation
g	=	Gram
G	=	Gravity
GAC	=	Granular Activated Carbon
hr	=	hour
HPSEC	=	High Pressure Size Exclusion Chromatography
kg	=	Kilogram
kL	=	Kilolitre
kPa	=	Kilo Pascal

L	=	Litre
m	=	Metre
m ²	=	Square metre
m ³	=	Cubic metre
MFI	=	Modified Fouling Index
mg	=	Milligram
mL	=	Millilitre
mm	=	Millimetre
MWD	=	Molecular Weight Distribution
MF	=	Microfiltration
N/A	=	Not applicable
NF	=	Nanofiltration
NOM	=	Natural Organic Matter
NTU	=	Nephelometric Turbidity Unit
Q1 – Q4	=	Quarter of the year
RO	=	Reverse Osmosis
RWOM	=	Rainwater Organic Matter
SWC	=	Sydney Water Corporation
T	=	time (s)
TC	=	Total carbon
TDS	=	Total Dissolved Solid
TIC	=	Total Inorganic Carbon
TMP	=	Trans-membrane Pressure
TOC	=	Total organic carbon
TSS	=	Total Suspended Solids
UF	=	Ultrafilter
µm	=	Micro metre
WHO	=	World Health Organisation
yr	=	Year

List of Publications

1. B. Kus, D. Pratheep, Jaya Kandasamy, S. Vigneswaran, H. K. Shon, G. Moody (2013) Reduction in water demand due to rainwater tanks in Sydney, Water Management, Proceeding of the institution of Civil Engineers, submitted for publication in February, 2013.
2. B. Kus, J. Kandasamy, S. Vigneswaran, H. K. Shon, and G. Moody (2013) Household rainwater harvesting system – pilot scale gravity driven membrane-based filtration system. Water Science and Technology, 13 (3) 790-797
3. B. Kus, J. Kandasamy, S. Vigneswaran, H. K. Shon, R. Sleigh and G. Moody (2012) Performance of granular medium filtration and membrane filtration in treating stormwater for harvesting and reuse. Desalination and Water Treatment, 45 (1-3) 120-127
4. G. Singh, M. A. H. Johir, J. Kandasamy, Dr. S. Vigneswaran, B. Kus, R. Naidu (2012) Stormwater Harvesting and Reuse, Encyclopaedia of Sustainability Science and Technology Robert A. Meyers (editor) pp 10095-10117 Springer Science DOI 10.1007/978-1-4419-0851-3_266
5. B. Kus, J. Kandasamy, S. Vigneswaran, H. K. Shon, R. Sleigh and G. Moody (2012) Two stage filtration for stormwater treatment: A Pilot scale study. Desalination and Water Treatment, 45 (1-3) 361-369
6. B. Kus, J. Kandasamy, S. Vigneswaran and H. K. Shon, (2011) Water Quality in Rainwater Tanks in Rural and Metropolitan Areas of New South Wales Australia. Journal of Water Sustainability, 1 (1) 33-44
7. B. Kus, J. Kandasamy, S. Vigneswaran and H. K. Shon, (2010) Analysis of First Flush to Improve the Water Quality in Rainwater Tanks. Water Science and Technology, 61 (2) 421-428

8. B. Kus, J. Kandasamy, S. Vigneswaran and H. K. Shon, (2010) Water quality characterisation of rainwater in tanks at different times and locations. *Water Science and Technology*, 61 (2) 429-439
9. B.Kus, (2009) First flush bypass the key to cleaner rainwater. Institute Of Engineers Australia – Water Engineering, Australia Edition, *Water Storage*, 3(7) August 2009
10. B. Kus and J. Kandasamy, (2009) Low-Cost Filtration System to Treat First-Flush Stormwater. Springer Netherlands - Earth and Environmental Science - Water, Air, and Soil Pollution, 9 (5-6) 347-355
11. L. Sabina, B. Kus, H.-K. Shon and J. Kandasamy, (2008) Membrane fouling propensity after adsorption as pretreatment in rainwater: a detailed organic characterisation. *Water Science and Technology*, 58 (8) 1535-1539

Abstract

Although most Australians receive their domestic supply from reticulated mains or town water there are vast areas with very low population densities with few reticulated supplies (ABS, 2001). In many of these areas, rainwater collected in tanks is the primary source of drinking water. Small amounts of contaminants found in drinking water may have a chronic effect on the health over a human's lifetime due to its cumulative effect. Heavy metals have recently become a major concern as their concentration in stored rainwater was found to exceed recommended levels and proved to be unsuitable for human consumption.

Even in areas that are serviced by town mains water, many households, schools, community and commercial centres collect rainwater in tanks to augment supplies or provide an alternative and sustainable source of water. Widespread water restrictions in cities such as Sydney and Brisbane in recent years have brought to prominence water conservation measures, including the use of rainwater tanks.

The aim of this project is to develop a cost effective filtration system to improve water quality in rainwater tanks.

Pollutants in rain tank water can be generically described as containing colloidal solids, some microbial pollutants and micro-pollutants. The pollutant characteristics of sampled values of rainwater tanks in the Sydney metropolitan and rural areas of New South Wales, Australia, was analysed to determine the critical pollutants and those that do not comply with the Australian Drinking Water Guidelines (ADWG, 2011). The results indicate that before treatment, the rainwater complied with many of the

parameters specified in the ADWG (2011), though as previous studies demonstrate certain pollutants have the potential at times to exceed the limits specified in ADWG (2011). Additionally the characteristics of the first flush of roof runoff and its impact on the quality of water stored in a rainwater tank is presented.

Demand management analysis was conducted using data obtained for residential households throughout Sydney. The analysis provides the water demand for residential households in individual LGAs in Sydney. It also, for the first time, defines the reduction in water demand in all Sydney LGAs as a result of installing rainwater tanks. Such data can be used to size the volume of the permeate storage tank which is an integral element of a rainwater tank treatment system.

An experimental study of an affordable adsorption and membrane based treatment system was carried out. This included investigating the long term performance of GAC adsorption filter as a pre-treatment to micro-filter membrane filtration used to treat raw rainwater.

On completion of laboratory studies, filtration systems were tested to determine the operational performance of various media filter and membrane filter systems at the stormwater harvesting plant at Carlton, Sydney. This plant harvests stormwater baseflow whose quality was comparable to rainwater. The results provide useful information of how a comparable treatment system can treat rainwater.

Finally a gravity driven pilot scale rainwater treatment system was developed and tested in a residential property in Sydney. The results of the performance monitoring of the system is presented. The outcome of the study demonstrated that the water quality in rainwater tanks can be improved through a simple yet effective GAC & membrane

filtration system driven only by the power of gravity leading to a cost effective setup that did not require expensive pumps and automation systems. The filter elements are periodically replaced to provide an ongoing high quality water supply.

