

Granular Activated Carbon (GAC) Biofilter in Water and Wastewater Treatment

**By
Thi To Loan Hoang**



University of Technology, Sydney

**Submitted in fulfillment for the degree of
Master of Engineering**

**Faculty of Engineering
University of Technology, Sydney (UTS)
Australia**

2005

CERTIFICATE

I certify that this thesis has not already been submitted for any degree and is not being submitted as part of candidature for any other degree.

I also certify that the thesis has been written by me and that any help that I have received in preparing this thesis, and all sources used, have been acknowledged in this thesis.

Production Note:

Signature removed prior to publication.

Signature of Candidate

ACKNOWLEDGEMENTS

I wish to express my foremost and deepest thanks to my supervisor, Professor Vigneswaran and co-supervisor Dr. Ngo for all their guidance and support during my study in UTS. They provided me precious knowledge and skills in the field of my research. They encouraged and supported me both in academic study and daily life. Thank you for spending time and effort for revising my works, especially this thesis.

I would like to thank David Hooper who helped me to solve technical problems in the laboratory. Thank you also to Dr. Chaudhary for helping me to get start with my work.

I really appreciated the assist of Dr. Shim in mathematic modelling. Thank you very much to Dr. Paul Peiris and Pavan at Western Sydney University for helping me in microbiological analysis. Thank you Prof. Takizawa for supporting me conducting experiments in Tokyo University, Japan.

I would like to express my gratitude to Ausaid for giving me the opportunity to come to Australia and study in UTS. Thank you for your financial and academic support during my scholarship both in Vietnam and Australia.

Thank you very much to all of students and staffs in the Environmental Engineering R&D laboratory (EEDL). Thank you to Wenshan, Rong, Ramesh, Vinh, Nathaporn, Paul, Hok, Laszlo, Cuong. They are like another family to me while I stayed in UTS.

I'd like also thank to undergraduate students, Dung, Alban, Nickhil, who helped me in conducting experiments in the lab.

Finally, I would like to thank you all my family and friends who encouraged me to overcome all difficulties to complete this thesis.

Table of contents

CHAPTER 1 INTRODUCTION	1-1
1.1 Overview	1-2
1.2. Objectives.....	1-3
1.3. Scope	1-4
CHAPTER 2. LITERATURE REVIEW	2-1
2.1 Organic matter in water and wastewater	2-2
2.1.1 General	2-2
2.1.2 Organic matter characteristics.....	2-3
2.3 Typical treatment technologies in removing organics from water and wastewater. 2-6	
2.3.1 Typical conventional treatment technology	2-6
2.3.2 Typical advanced water and waste water treatment technology	2-7
2.4 Biological filtration	2-8
2.4.1 General	2-8
2.4.2 Adsorption mechanisms	2-9
2.4.2.1 Equilibrium	2-10
2.4.2.2 Kinetics of adsorption	2-13
2.4.2.3 Fixed bed adsorption	2-14
2.4.3 Biological attachment processes	2-15
2.5 Factors influencing on biological filtration.....	2-19
2.5.1 General	2-19
2.5.2 Filter media	2-19
2.5.3 Empty bed contact time (EBCT) and hydraulic loading rate	2-21
2.5.4 Influent characteristics	2-22
2.5.5 Backwash	2-23
2.5.6 Temperature	2-24
2.5.7 Others	2-25
2.6 Microbiological community in biofilter.....	2-26
2.6.1 General	2-26

2.6.2 Biofilm thickness	2-26
2.6.3 Biofilm density.....	2-27
2.6.4 Biofilm composition	2-27
2.6.5 Microbiological growth in biological processes	2-29
2.6.5.1 Kinetics of microbiological growth	2-29
2.6.5.2 Biological filtration modeling.....	2-32
CHAPTER 3. EXPERIMENTAL INVESTIGATION	3-1
3.1 Introduction.....	3-2
3.2 Materials.....	3-2
3.2.1 Wastewaters and water used in the experiments and their characteristics.....	3-2
3.2.2 Filter media	3-4
3.3 Experimental set-up	3-6
3.4 Analytical methods.....	3-9
3.4.1 Total organic carbon measurement	3-9
3.4.2 Adsorption analysis.....	3-10
3.4.3 Biological measurement.....	3-13
3.4.4 Microbiological analysis	3-15
CHAPTER 4. RESULT AND DISCUSSION	4-1
4.1 GAC adsorption	4-2
4.1.1 Adsorption equilibrium	4-2
4.1.2 Adsorption kinetics	4-4
4.1.3 Fixed bed adsorption column.....	4-6
4.2 Long term performance of GAC biofilter	4-9
4.2.1 Long term performance of GAC biofilter with synthetic wastewater.....	4-9
4.2.2 Long term performance of GAC biofilter with river water.....	4-11
4.3 Mathematical modeling of GAC biofilter.....	4-13
4.4 Effect of operational conditions on the performance of GAC biofilter	4-19
4.4.1 Effect of filtration rate.....	4-19
4.4.2 Effect of influent concentration	4-22
4.5 Biomass in GAC biofilter	4-25
4.5.1 Biomass accumulation	4-25

4.5.2 Biomass detachment by backwashing.....	4-32
4.5.3 Microbiological activity in biofilter.....	4-34
4.6 Microbiological assessment of GAC biofilter.....	4-40
4.6.1 Total coliforms	4-40
4.6.2 Total fecal coliforms	4-42
4.6.3 Microbiological identification in GAC biofilter	4-43
4.7 Comparison of the effectiveness of GAC and other filter media in biofilter.....	4-45
4.8 Performance of the combined system of GAC - sponge biofilter.....	4-46
4.8.1 GAC- unsaturated sponge biofilter	4-47
4.8.2 GAC- saturated sponge biofilter	4-48
4.9 Performance of the combined system of GAC – floating medium biofilter	4-50
CHAPTER 5. CONCLUSION	5-1
5.1 GAC biofilter in water and wastewater treatment.....	5-2
5.1.1 GAC bioadsorption mechanisms and models	5-2
5.1.2 Biomass growth on GAC filter	5-2
5.1.3 Design and operational conditions of GAC biofilter	5-3
5.1.4 Performance of GAC	5-3
5.2 Combined system of GAC and one other filter medium biofilter in water and wastewater treatment.....	5-4
REFERENCE	R-1
APPENDIX.....	A-1
Appendix A. Pilot scale biofilter.....	A-1
Appendix B. Bacterial identification using BIOLOG system.....	A-4

Nomenclature

- A = the specific surface area of the media
- ATP = adenosine triphosphate
- BOD₅ = biochemical oxygen demand
- b_{tot} = Total biofilm loss efficient (s^{-1})
- $btot$ = the total biofilm loss coefficient
- C = the liquid phase concentration.
- C_0 = initial TOC concentration of synthetic wastewater (mg/L)
- C_e = the equilibrium organic concentration (mg/L)
- COD = chemical oxygen demand
- CFU = Number of Colony forming units
- D_{ax} = the axial dispersion coefficient
- DBPs =disinfection by products
- D_f = the molecular diffusivity within biofilm
- D_L = axial dispersion coefficient
- DNA = deoxyribonucleic acid
- DO = Dissolved oxygen
- DOC = dissolved organic matter
- D_s = diffusion coefficient (m^2/s)
- D' = the dispersion coefficient (m^2/s)
- EBCT = empty bed contact time
- EPS = extracellular polysaccharides
- GAC = granular activated carbon
- H = Henry law's constant

HAA	=	haloacetic acids
HLR	=	Hydraulic loading rate
J_f	=	the flux of substrate into the biofilm (mg/m ² /s)
k	=	the maximum rate of substrate utilization (mg/mg/s)
K	=	reaction constant
K_d	=	Decay coefficient (s ⁻¹)
K_f	=	film mass transfer coefficient (m/s)
K_s	=	Solid phase mass transfer
K_s	=	the Monod half-velocity coefficient (mg/L)
K_{max}	=	Maximum rate of substrate utilization
k_p	=	the particle phase mass transfer coefficient
L	=	reaction constant
LDFA	=	Linear driving force approximation
L_f	=	the biofilm thickness
L_{f0}	=	Biofilm thickness (m)
M	=	the weight of used GAC (g)
MW	=	Molecular weight (Dalton)
NDIR	=	Non-dispersive infrared gas reactor
N	=	The adsorbate uptake rate per pellet
P_n	=	the number of characteristic packing spheres.
NOM	=	natural organic matter
q	=	the adsorbed-phase concentration
q_m	=	saturation amount of organic adsorbed (mg/g)
q_s	=	the value of q at pellet surface

RNA	=	ribonucleic acid
S	=	substrate concentration (mg/L)
TOC	=	Total organic carbon (mg/L)
TC	=	Total carbon (mg/L)
TIC	=	Total inorganic carbon (mg/L)
THMs	=	trihalomethanes
u	=	the interstitial velocity
V	=	the volume of solution (mL)
VSS	=	volatized suspended solids
x	=	the distance along the biofilter length (m)
X_f	=	the cell density of biofilm
X_{susp}	=	the suspended cell concentration (mg/L)
Y	=	Yield coefficient (mg/mg)
β	=	the filtration efficiency
σ	=	the biofilm shear loss coefficient (s^{-1})
ε_b	=	the bed porosity
μ	=	specific growth rate
μ_m	=	the maximum growth rate
θ	=	the empty bed contact time
v	=	fluid velocity (m/s)
ψ	=	organic concentration spreading parameter

List of Tables

Table 3.1 Constituents of synthetic wastewater used.....	3-3
Table 3.2 Characteristics of river water used (Hawkesbury River).....	3-4
Table 3.3 Physical properties of GAC (Calgon Carbon Corp., USA)	3-4
Table 3.4 Physical properties of Anthracite.....	3-5
Table 3.5 Properties of sponge (polyurethane foam).....	3-6
Table 4.1 Equilibrium adsorption isotherm parameters.....	4-2
Table 4.2 Kinetics adsorption parameters of LDFA model for GAC adsorption.....	4-5
Table 4.3 Experimental conditions and physical parameters calculated for of GAC fixed bed adsorption.	4-7
Table 4.4 Parameters and equations for modeling biological filtration process.....	4-14
Table 4.5 Physical parameters used for theoretical predictions in GAC biofilter	4-16
Table 4.6 Biological parameters used in the GAC biofiltration modelling	4-17
Table 4.7 Viable cell count in GAC column fed with synthetic wastewater (column diameter = 2cm, GAC bed depth = 15cm, filtration rate = 2m/h).....	4-31
Table 4.8 Viable cell count in GAC column fed with Hawkesbury River water (column diameter = 2cm, GAC bed depth = 15cm, filtration rate = 2m/h).....	4-32
Table 4.9 Viable cell count in backwashed water (column diameter = 2cm, GAC bed depth = 5cm, backwashing expansion = 60%, backwash duration = 2minutes).....	4-34
Table 4.10 Total Coliforms of influent and effluent of GAC biofilters for synthetic wastewater and river water.....	4-41
Table 4.11 Total fecal coliforms of influent and effluent of GAC biofilters for synthetic wastewater and river water.....	4-42
Table 4.12 Microbial identification on GAC in biofilter	4-43

List of Figures

Figure 2.1 Comparison between Langmuir and Freundlich isotherm (Cooney, 1999) ..	2-12
Figure 2.2 Schematic of biofilm formation (Percival et al., 2000)	2-15
Figure 2.3 A sample of relation of bacteria growth and nutrient concentration in a batch test	2-30
Figure 2.4 Typical bacterial growth pattern (Tchobanoglous and Burton, 1991).....	2-31
Figure 3.1 Schematic diagram of lab-scale GAC/anthracite biofilter experimental set-up	3-7
Figure 3.2 Schematic diagram of GAC-sponge biofilter experimental set up	3-7
Figure 3.3 Experimental set-up of GAC-floating medium biofilter	3-8
Figure 3.4 Multi N/C 2000 analyzer (Analytik Jena AG).....	3-10
Figure 3.5 Schematic of the batch experiment using Jar test apparatus	3-12
Figure 3.6 Biological oxygen monitor (Yellow Springs Instrument, YSI probe Model 5300)	3-14
Figure 4.1 Adsorption equilibrium of synthetic wastewater by GAC with different isotherm models (contact time =72 hours, mixing rate = 130 rpm, temperature = 25 ⁰ C)	4-3
Figure 4.2 Adsorption kinetics of GAC with organic matter in synthetic wastewater (average TOC of synthetic wastewater = 10 mg/L, mixing rate = 130rpm)	4-4
Figure 4.3 Prediction of adsorption kinetics of GAC in batch system with LDFA model (average TOC of synthetic wastewater = 10 mg/L, mixing rate = 130rpm)	4-6
Figure 4.4 Adsorption kinetics results with GAC fixed bed adsorption column. (filtration rate = 2m/h, average TOC of influent = 10mg/L).....	4-8
Figure 4.5 TOC removal efficiency of the GAC biofilter with different filter bed depths (filtration rate =2 m/h, column diameter = 2 cm, average influent TOC = 10mg/L).	4-10

Figure 4.6 TOC removal by GAC biofilter with Hawkesbury river water (filtration rate= 2m/h, bed depth =15cm, average TOC of river water= 6 mg/L)	4-12
Figure 4.7 Experimental and simulated TOC values (synthetic wastewater, influent TOC = 11.6 mg/L, filtration rate = 2m/h, daily backwashing)	4-18
Figure 4.8 Effect of filtration rate on the performance of GAC biofilter at different bed depths (filter acclimatization at 2m/h for 42 days prior to this experiment; average TOC = 10 mg/L, column diameter = 2 cm)	4-21
Figure 4.9 Effect of influent concentration on the performance of GAC biofilter with different bed depths (Filter acclimatization at 2m/h, average TOC influent = 10 mg/L, column diameter = 2 cm)	4-24
Figure 4.10 Biomass accumulation in GAC with synthetic wastewater in batch mode (GAC = 1g/L mg, average influent TOC = 10 mg/L).....	4-26
Figure 4.11 Dry mass accumulation in GAC biofilter (GAC bed depth = 5 cm, filtration rate = 2m/h, average influent TOC = 10 mg/L)	4-27
Figure 4.12 Comparison of biomass accumulation onto GAC in column and batch experiment.....	4-28
Figure 4.13 Viable cell growth on GAC in batch test with synthetic wastewater	4-29
Figure 4.14 Viable cell growth on GAC in batch test with river water	4-30
Figure 4.15 A comparison of total dry mass accumulation and the amount of mass detached by backwashing in GAC biofilter (GAC bed depth = 5 cm, filtration rate = 2m/h, influent = synthetic wastewater, average influent TOC = 10 mg/L, backwashing expansion = 60%, backwash duration = 2minutes).....	4-33
Figure 4.16 The change of dissolved oxygen content of samples during 30 minutes of respiratory measurement	4-36
Figure 4.17 DO consumption of microbes on GAC in biofilter (diameter = 2cm, bed depth =5cm, filtration rate = 2m/h, TOC influent = 10mg/L; DO consumption in 30 minutes)	4-36

Figure 4.18 Relation between dissolved oxygen consumption rate and TOC removal by GAC biofilter (diameter = 2cm, bed depth =5cm, filtration rate = 2m/h, TOC influent = 10mg/L).....	4-37
Figure 4.19 Relationship between biomass and oxygen consumption rate of fixed biofilm (oxygen consumption rate was measured in 30 minutes)	4-39
Figure 4.20 Comparison of different filter media for organics removal (average influent TOC = 10 mg/L, bed depth = 30cm, filtration rate = 2m/h)	4-45
Figure 4.21 TOC removal by GAC-unsaturated sponge biofilter during steady state (filtration rate = 2m/h, average TOC of feeding water =10mg/L).....	4-48
Figure 4.22 TOC removal by GAC-saturated sponge biofilter during steady state (filtration rate = 2m/h, average TOC of feeding water =10mg/L)	4-49
Figure 4.23 TOC removal by GAC-floating media system (filtration rate = 2m/h, average TOC of feeding water =10mg/L)	4-50

Abstract

Biofilters can effectively remove organic matters from water and wastewater. Basically, the success of operation of a biofilter depends mainly on the activities of the microbial community in the filter. Organic substances are adsorbed onto filter media and then biodegraded by those microbes.

The experimental investigation of the granular activated carbon (GAC) adsorption indicated that GAC exhibited a high organic removal rate by adsorption in both the batch and column experiments. The GAC adsorption equilibrium with synthetic wastewater fitted better with association theory (Talu) than with Freundlich and Sips models. Adsorption kinetics and fixed bed of GAC with organic matter was well described and predicted by the Linear Driving Force Approximation (LDFA) model. Long term GAC biofiltration was mathematically described using a simple model which incorporated both adsorption and biodegradation. The model was mainly successful in describing the biological phase.

Biomass accumulation onto GAC was evaluated in terms of dry mass and number of viable cells both in the batch and column experiments. The attachment of micro-organisms onto the GAC surface depended on the hydraulic loading rate and influent concentration. The amount of dry mass retained on GAC in the column was double than that in batch test in the steady state with 44mg/g GAC and 85mg/g GAC respectively. More viable cells were enumerated from GAC in the experiments with synthetic wastewater than with river water. The prominent bacteria isolated from GAC biofilter for synthetic wastewater and river water included: *Pseudomonas Aeruginos*, *Pseudomonas Alcaligenes*, *Brevibacterium Otitidis*, *Enterobacter Cloacae*, *Enterobacter Aerogenes*, *Staphylococcus Epidermidis* and *Kocuria Rosea*.

The long term performance of the GAC biofilter with synthetic wastewater which has similar characteristics to biologically treated sewage effluent and river water was experimentally evaluated. The result showed that the GAC biofilter could maintain high

organic removal efficiency after a long filtration time without any regeneration of activated carbon. Even after 42 days of continuous run, the biofilter of very short depth of 15cm GAC bed depth maintained a consistent organic removal efficiency of 40-50% with synthetic wastewater and 55% with river water. GAC biofilter also removed 60-98% of total coliforms from synthetic wastewater and river water. Especially, no fecal coliforms were detected in effluent from the GAC biofilter for river water.

The daily backwash adopted to avoid the physical clogging of the biofilter did not have significant effect on the performance of the filter. The change of filter bed depths, filtration rates and influent concentrations affected the performance of the GAC biofilter. Total organic carbon (TOC) removal efficiency in the higher filter bed was significantly better than that with shallow bed depth (60% TOC removal with a 30cm- bed depth while only 30% with a 5 cm - bed depth). As expected, the efficiency in organic removal decreased with an increase in the filtration rate. The difference was more significant in the lower bed. TOC removal efficiency of the biofilter was also affected by the concentration of influent. It increased with the increase in the concentration of influent, but the TOC removal pattern with time was almost the same. Further, the increase of organic removal rate was not proportional to the rise of influent concentration.

A study with different filter media showed that GAC as filter media was superior to plastic bead, anthracite and sponge in terms of organic removal. In addition, GAC was combined with sponge or polypropylene as medium to enhance the effectiveness of biofilter in removing organic matter. The use of sponge and floating media can eliminate further 10-20% of TOC from the effluent of GAC biofilter with less effort in installation, operation and maintenance.

In summary, GAC biofilter can be used as an economical treatment system in removing organic matters and pathogens from biologically treated wastewater and surface water. The merits of GAC biofilter are the consistent of TOC removal efficiency, long life cycle, and simplicity in operation. The combined system of GAC - sponge filter media biofilter can be an effective and a good practical solution for improving the organic removal from water and wastewater.