

Table list:

Table 1 Impacts of MCBF and coagulant dosing sequence on floc D_f during floc growth, breakage and regrowth processes for HA and FA simulated water treatment

Table 1 Impacts of MCBF and coagulant dosing sequence on floc D_f during floc growth, breakage and regrowth processes for HA and FA simulated water treatment

Coagulant dose (mg/L)	Before breakage	After breakage	After regrowth
	D_f of HA flocs		
8	2.39	2.64	2.63
8+1	2.39	2.54	2.52
1+8	2.32	2.58	2.59
17	2.62	2.75	2.76
17+1	2.55	2.66	2.63
1+17	2.84	2.91	2.91
	D_f of FA flocs		
15	2.54	2.71	2.69
15+1	2.45	2.62	2.63
1+15	2.48	2.64	2.64
30	2.70	2.81	2.82
30+1	2.63	2.79	2.77
1+30	2.61	2.74	2.74

*8+1: 8 mgTiCl₄/L+1.0 mg MCBF/L; 1+8: 1.0 mg MCBF/L+ 8 mgTiCl₄/L